



Ref. Certif. No

NO132634

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

LED Power Supply

Name and address of the applicant

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD
West Zone, Ji An County Industrial Park, Ji an County
Jiangxi Province
China

Name and address of the manufacturer

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD
West Zone, Ji An County Industrial Park, Ji an County
Jiangxi Province
China

Name and address of the factory

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD
West Zone, Ji An County Industrial Park, Ji an County
Jiangxi Province
China

Note: When more than one factory, please report on page 2

 Additional Information on Page 2

Ratings and Principal characteristics

PRI: Max. 0.38 A, 220-240 V~, 50/60 Hz, SEC: Max. 60.9 W, max. 1.5 A, 15-58 Vd.c. (under load), Max. 68 Vd.c. (no-load).
(EAGLERISE), (ASTRAPOWER)

Trademark /Brand (If any)



Customer's Testing Facility (CTF) Stage used

Model/Type Ref

LS-xx-yyy LI1 EXC, LS-60-yyy LI EXC

Additional information (If necessary may also be reported on Page 2)

 Additional Information on Page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017
IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

REP066678

This CB Test Certificate is issued by the National Certification Body

Philip Pedersen vei 11,
NO-1366 Lysaker, Norway
Date: 20-11-2024Signature: Yasaman Vadoudi
Certification department



Ref. Certif. No

NO132634

Additional Information (if necessary)

Independent type, SELV, constant current output, thermal protected 110 °C, ta: 45 °C, tc: 75 °C/ 80 °C/ 85 °C/ 90 °C.

Independent controlgear providing SELV output for LED module only, constant current output, the insulation between live parts and enclosure fulfils reinforced insulation, IP20, for indoor only.

Thermal protected 110 °C for all models except LS-60-yyyy LI EXC.

LS-xx-yyy LI1 EXC:

The 'xx' in the type designation can be 8, 12, 15 or 21.

The 'yyy' is for the output current and represents the number from 70 to 550, for example, 70 means the output current is 70 mA, 550 means the output current is 550 mA.

LS-60-yyyy LI EXC:

The 'yyyy' is for the output current and represents the number from 1050 to 1500, for example, 1050 means the output current is 1050 mA, 1500 means the output current is 1500 mA.



Philip Pedersen vei 11,
NO-1366 Lysaker, Norway

Date: 20-11-2024

Signature: Yasaman Vadoudi
Certification department